

Device label Reference	Signal label Loc./Channel	Position -31202: HX-31200 HP Block 2 Intermediate		Signal label Loc./Channel	Device label Reference
1					1
2					2
3					3
4					4
5					5
6	US-30002-1 Liquefaction Mode ON -30002 / 3.15	S			6
7					7
8	U-30600_int-0 CC Mode ON -30600 / 11.19	int 0/1			8
9					9
10	GI-31201 HX-31200 HP Inlet	I			10
11	GI-31201_TV1 Valve open	TV1 98%			11
12					12
13					13
14					14
15					15
16					16
17					17
18	US-30022-1 Turbine String #2 Mode ON -30022 / 3.15	S			18
19					19
20	-31202_Up Ramp Speed Fast	_Up 2%/s			20
21	-31202_Dwn Ramp Speed Slow	_Dwn 0.2%/s			21
22					22
23					23
24					24
25					25
26					26
27					27
28					28
29					29
30					30
31					31
32					32

only active, if Liq ON and CC OFF

Rev.	Date	Prep.	Check.	Appr.	Description	 Linde Kryotechnik AG	Project No.:	K.00525	Page:	-31202 / 1
2	15.12.2020	N. Kolev	N. Kolev	N. Kolev	As built		Project:	LUND-ACCP15	Of:	-31202 / 1
1	15.12.2020	N. Kolev	N. Kolev	N. Kolev	Revision number update		Customer:			
0	16.08.2016	HIJ	HIJ	REM	For Logic Design Review		Order:			